

9/5/02

**Southern California Water Company**  
**Total Chromium and Chromium VI Results**  
**Coastal District Systems**

*DLR = 10 µg/L*

<b>Total Chromium</b> Groundwater Samples Samples taken Quarters 1 1996 - 1997 & 01-02		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Los Osos	<b>ND - 11 µg/L</b>	<b>ND</b>
Edna Rd	<b>ND</b>	<b>ND</b>
Ojai	<b>ND</b>	<b>ND</b>
Lake Marie	<b>ND</b>	<b>ND</b>
Nipomo	<b>ND</b>	<b>ND</b>
Orcutt	<b>ND</b>	<b>ND</b>
Sisquoc	<b>ND</b>	<b>ND</b>
Tanglewood	<b>ND</b>	<b>ND</b>
Simi Valley	<b>ND</b>	<b>ND</b>

ND = Not Detected      \*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed      µg/L = Unit of Measurement / Part Per Billion

\* Please note: The California Department of Health Services has recommended using the DLR of 10 µg/L for Total Chromium.

*DLR = 1µg/L*

<b>Chromium VI</b> Groundwater Samples Cr VI was not analyzed.		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Los Osos	<b>NA</b>	<b>NA</b>
Edna Rd	<b>NA</b>	<b>NA</b>
Ojai	<b>NA</b>	<b>NA</b>
Lake Marie	<b>NA</b>	<b>NA</b>
Nipomo	<b>NA</b>	<b>NA</b>
Orcutt	<b>NA</b>	<b>NA</b>
Sisquoc	<b>NA</b>	<b>NA</b>
Tanglewood	<b>NA</b>	<b>NA</b>
Simi Valley	<b>NA</b>	<b>NA</b>

ND = Not Detected      \*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed      µg/L = Unit of Measurement / Part Per Billion

\* Please note: The California Department of Health Services has recommended using the DLR of 1 µg/L for Chromium VI.