

9/5/02

Southern California Water Company
Total Chromium and Chromium VI Results
Foothill District Systems

DLR = 10 µg/L

<i>Total Chromium</i> <i>Groundwater Samples</i> <i>Samples taken Qtr-4 2000, & Qtr-2 2002</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Claremont	ND	ND
San Dimas	ND	ND
South Arcadia	ND	ND
South San Gabriel	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 10 µg/L for Total Chromium.

DLR = 1µg/L

<i>Chromium VI</i> <i>Groundwater Samples</i> <i>Samples taken Qtr-4 2000 & Qtr-2 2002</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Claremont	ND - 8.7 µg/L	2.6
San Dimas	ND - 1.8 µg/L	ND
South Arcadia	ND - 8.2 µg/L	4.2 µg/L
South San Gabriel	2.9 µg/L - 10 µg/L	5.8 µg/L

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 1 µg/L for Chromium VI.