

9/5/02

Southern California Water Company
Total Chromium and Chromium VI Results
Mountain Desert District Systems

DLR = 10 µg/L

Total Chromium		
<i>Groundwater Samples</i>		
<i>Samples taken Q2 2002</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Barstow	ND	ND
Morongo Del Norte	ND	ND
Morongo Del Sur	ND	ND
Calipatria	ND	ND
Niland	ND	ND
Wrightwood	ND	ND
Victorville 1	ND	ND
Victorville 3	ND	ND
Victorville 5	ND	ND
Victorville 6	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 10 µg/L for Total Chromium.

DLR = 1µg/L

Chromium VI		
<i>Groundwater Samples</i>		
<i>Samples taken Q2 2002</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Barstow	ND - 1.6 µg/L	ND
Morongo Del Norte	1.4 µg/L - 1.5 µg/L	1.45 µg/L
Morongo Del Sur	4.8 µg/L- 4.8 µg/L	4.8 µg/L
Calipatria	NA	NA
Niland	NA	NA
Wrightwood	ND	ND
Victorville 1	1.3 µg/L - 6.7 µg/L	2.7 µg/L
Victorville 3	3.0 µg/L- 4.7 µg/L	3.9 µg/L
Victorville 5	1.7 µg/L - 2.0 µg/L	1.9 µg/L
Victorville 6	2.0 µg/L- 4.8 µg/L	3.1 µg/L

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 1 µg/L for Chromium VI.