

9/5/02

Southern California Water Company
Total Chromium and Chromium VI Results
Northern District Systems

DLR = 10 µg/L

<i>Total Chromium</i>		
<i>Groundwater Samples</i>		
<i>Samples taken Q1 of 2001 & Q1 of 2002.</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Arden	ND	ND
Cordova	ND - 11.0 µg/L	ND
Bay Point	ND - 11.0 µg/L	ND
Clearlake	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 10 µg/L for Total Chromium.

DLR = 1 µg/L

<i>Chromium VI</i>		
<i>Groundwater Samples</i>		
<i>Samples taken Q1 of 2001 & Q1 of 2002.</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Arden	2.7 µg/L - 5.5 µg/L	3.9 µg/L
Cordova	ND - 2.5 µg/L	0.9 µg/L
Bay Point	ND - 7.9 µg/L	2.4 µg/L
Clearlake	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 1 µg/L for Chromium VI.