

9/5/02

Southern California Water Company
Total Chromium and Chromium VI Results
Orange County District Systems

DLR = 10 µg/L

<i>Total Chromium</i> <i>Groundwater Samples</i> <i>Samples taken During 2001</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Placentia	ND	ND
Cowan Heights	ND	ND
West Orange County	ND	ND
Yorba Linda	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 10 µg/L for Total Chromium.

DLR = 1 µg/L

<i>Chromium VI</i> <i>Groundwater Samples</i> <i>Samples Taken During 2001</i>		
<i>System Name</i>	<i>Range of Detection</i>	<i>Average Level</i>
Placentia	ND - 1.3 µg/L	ND
Cowan Heights	ND	ND
West Orange County	ND - 3.2 µg/L	1 µg/L
Yorba Linda	ND	ND

ND = Not Detected

*DLR = Detection Limits for Purposes of Reporting

NA= Not Analyzed

µg/L = Unit of Measurement / Part Per Billion

* Please note: The California Department of Health Services has recommended using the DLR of 1 µg/L for Chromium VI.