



NOTES :

1. INSTALL BACKFLOW PREVENTION DEVICE PER REQUIREMENTS OF CROSS-CONNECTION CONTROL POLICY.
2. VAULT SHALL HAVE A TORSION OR SPRING ASSISTED LID

METER DIMENSIONS SIZE	METER DIMENSIONS			SPOOL SIZE	MINIMUM VAULT SIZE
	A	B	C		
4"	8"	15"	33"	4"x18"	4'x5'
6"	10 1/4"	19 1/2"	45"	6"x18"	5'x6'
8"	12 1/4"	21 3/4"	53"	8"x18"	5'x7'
10"	13 3/4"	22 1/2"	68"	10"x18"	5'x8'

SOUTHERN CALIFORNIA WATER COMPANY

DRAWN BY: JEFF BERG DATE: 8/96

REVISED: _____

4", 6", 8" OR 10"
DUAL PURPOSE DOMESTIC
FIRE SERVICE METER ASSEMBLY

STANDARD DRAWING NO. 4.9