



NOTES:

- 1) DEVELOPER SHALL INSTALL AN APPROVED DOUBLE CHECK VALVE ASSEMBLY.
- 2) ASSEMBLY MUST BE ACCESSIBLE FOR TESTING AND MAINTENANCE.
- 3) ALL NEWLY INSTALLED BACKFLOW PREVENTION ASSEMBLIES MUST BE TESTED IN ACCORDANCE WITH LOCAL ORDINANCE PRIOR TO BEING PUT IN SERVICE.

SOUTHERN CALIFORNIA WATER COMPANY

DRAWN BY: JEFF BERG DATE: 8/96

REVISED:

DOUBLE CHECK VALVE ASSEMBLY

STANDARD DRAWING NO. 6.4